



National Kidney and Transplant Institute
Bids and Awards Committee
 East Avenue, Quezon City 1100
 981-0300 / 981-0400 local 1157
<http://www.nkti.gov.ph/>

SUPPLEMENTAL BID BULLETIN NO. 21-103-1

ONE (1) LOT SUPPLY AND DELIVERY OF LABOR, TOOLS, MATERIALS, CONSUMABLES, SUPERVISION AND TECHNICAL EXPERTISE FOR THE INSTALLATION, TESTING AND COMMISSIONING OF ONE (1) UNIT BRAND NEW 1500KVA POWER TRANSFORMER INCLUDING DISMANTLING, DECOMMISSIONING AND TRADE-IN OF OLD AND DEFECTIVE UNIT AT DIAGNOSTIC POWER CENTER

Bid Reference IB No. 21-103

This Supplemental Bid Bulletin **No. 21-103-1** is being issued to inform all the prospective bidders on the following amendment:

- a. **Section III. Bid Data Sheet**
Please see attached Revised Bid Data Sheet
- b. **Section V. Special Conditions of Contract**
Please see attached Revised Special Conditions of Contract
- c. **Section VI. Specifications**
Please see attached Revised Specifications
- d. **Mandatory Forms**
Please see attached Revised Mandatory Forms
- e. **Change in the Number of Project Completion**

FROM	TO
90 Calendar Days	120 Calendar Days

This Supplemental Bid Bulletin including Annexes, if any, shall form part of the Bid Documents. Any provisions in the Bid Documents inconsistent herewith is hereby amended, modified, and superseded accordingly.

For guidance and information of all concerned.

Issued this 9th day of July 2021 in Quezon City.

(SGD)VIOLETA M. VALDERRAMA, MD
BAC, Chairperson

Received by: (PLS SIGN) _____

Bidder's Name: (PLS PRINT) _____

Date: _____

Revised Mandatory Forms

NKTI Reference No. IB 21-103

Name of Procuring Entity: NATIONAL KIDNEY AND TRANSPLANT INSTITUTE

Name of Project: _____

STATEMENT OF ONGOING GOVERNMENT & PRIVATE CONTRACTS INCLUDING CONTRACTS AWARDED BUT NOT YET STARTED

Business Name : _____

Business Address : _____

Name of Contract/Location Project Cost	a. Owner Name b. Address	Nature of Work	Contractor's Role		a. Date Awarded b. Date Started	% of Accomplishment		Value of Outstanding Works/Uncompleted Portion
			Description	%		Planned	Actual	
<u>Government</u>								
<u>Private</u>								
							Total Cost	

*Continue in a separate sheet if necessary..

Note: This statement shall be supported with:

- 1 Notice of Award and/or Contract
- 2 Notice to Proceed issued by the owner
- 3 Certificate of Accomplishments signed by the owner or authorized representative

Submitted by : _____
(Printed Name and Signature)

Designation : _____

Date : _____

SUBSCRIBED AND SWORN to before me this ___ day of **[month] [year]** at **[place of execution]**, Philippines. Affiant/s is/are personally known to me and was/were identified by me through competent evidence of identity as defined in the 2004 Rules on Notarial Practice (A.M. No. 02-8-13-SC). Affiant/s exhibited to me his/her **[insert type of government identification card used]**, with his/her photograph and signature appearing thereon.

Witness my hand and seal this ___ day of **[month] [year]**.

NAME OF NOTARY PUBLIC

Serial No. of Commission _____

Notary Public for _____ until _____

Roll of Attorneys No. _____

PTR No. __, *[date issued]*, *[place issued]*

IBP No. __, *[date issued]*, *[place issued]*

MCLE Accreditation No. _____


MCLE Expiration Date _____

Doc. No. ____

Page No. ____

Book No. _____

Series of 2019





Revised Section III. Bid Data Sheet

ITB Clause	
5.2	For this purpose, contracts similar to the Project refer to contracts which have the same major categories of work, which shall be: “Electrical Works”
5.4	<p>The following persons/entities shall be allowed to participate in this Project:</p> <ul style="list-style-type: none">a) Duly licensed Filipino citizens/sole proprietorships; orb) Partnerships duly organized under the laws of the Philippines and of which at least sixty percent (60%) of the interest belongs to citizens of the Philippines;orc) Corporations duly organized under the laws of the Philippines, and of which at least sixty percent (60%) of the outstanding capital stock belongs to citizens of the Philippines;ord) Cooperatives duly organized under the laws of the Philippines; ore) Persons/entities forming themselves into a joint venture, i.e., a group of two (2) or more persons/entities that intend to be jointly and severally responsible or liable for a particular contract: Subject to Executive Order No. 65 (EO 65), s. 2018. (Correlate with Clause 10.1 (g) and Clause 10.3.of the BDS) <p>NOTE: the persons/entities enumerated above may participate in competitive bidding if he has been issued a license by the PCAB to engage or act as a contractor. (Please see 23.4.2.1)</p> <ul style="list-style-type: none">f) Foreign bidders may be eligible to participate in the procurement of Infrastructure Projects when provided for under any Treaty or International or Executive Agreement as provided in Section 4 of the Act and this IRR; (Please see 23.4.2.2)g) The prospective bidder must have completed an SLCC that is similar to the contract to be bid, and whose value, adjusted to current prices using the PSA consumer price indices, must be at least fifty percent (50%) of the ABC to be bid.(Please see 23.4.2.3) Correlate with Clause 10.1 (f) of the BDS. <p>The SLCC shall be supported by an Owner’s Certificate of Final Acceptance issued by the project owner other than the contractor or a final rating of at least Satisfactory in the Constructors Performance Evaluation System (CPES). In case of contracts with the private sector, an equivalent document shall be submitted.(Please see 23.4.2.5)</p> <ul style="list-style-type: none">h) The computation of a prospective bidder’s NFCC must be at least equal to the ABC to be bid. (Please see 23.4.2.6) Correlate with Clause 10.1 (i) of the BDS.



7.1	Sub-Contracting Shall Not Be Allowed
10.1	<p>Section IX. Checklist of Technical and Financial Documents.</p> <p><u>Legal Documents</u></p> <p>(a) Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages); or</p> <p>(b) Registration certificate from Securities and Exchange Commission (SEC), Department of Trade and Industry (DTI) for sole proprietorship, or Cooperative Development Authority (CDA) for cooperatives or its equivalent document; and</p> <p>(c) Valid Mayor's or Business permit issued by the city or municipality where the principal place of business of the prospective bidder is located, or the equivalent document for Exclusive Economic Zones or Areas; and</p> <p>(d) Valid Tax Clearance Certificate per E.O. No. 398, s. 2005, as finally reviewed and approved by the Bureau of Internal Revenue (BIR).</p> <p><u>Technical Documents</u></p> <p>(e) Notarized Statement of the prospective bidder of all its ongoing government and private contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid; and</p> <p>(f) Notarized Statement of the bidder's Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided under the rules; and</p> <p>(g) Philippine Contractors Accreditation Board (PCAB) License - For Government Projects; or Special PCAB License in case of Joint Ventures; (Correlate with 10.3)</p> <p>and registration for the type and cost of the contract to be bid; (Please refer to Clause 10.3 for details) and</p> <p>(h) Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission;or Original copy of Notarized Bid Securing Declaration;</p>



Republic of the Philippines
National Kidney and Transplant Institute
Bids and Awards Committee
East Avenue, Quezon City 1100
8981-0300 / 9881-0400 local 1156/1186
<http://www.nkti.gov.ph/>

and

- (i) Project Requirements, which shall include the following:
- (i) **Organizational chart** for the contract to be bid;
 - (ii) **List of contractor's key personnel** (*e.g.*, Electrical Engineer and Construction Safety and Health Officer), to be assigned to the contract to be bid, with their complete qualification and experience data;
 - (iii) **List of contractor's major equipment** units, which are owned, leased, and/or under purchase agreements, supported by proof of ownership or certification of availability of equipment from the equipment lessor/vendor for the duration of the project, as the case may be;

and

- (j) Original duly signed **Omnibus Sworn Statement (OSS)**;

and

if applicable, Original Notarized Secretary's Certificate in case of a corporation, partnership, or cooperative;

or

Original Special Power of Attorney of **all members** of the Joint venture giving full power and authority to its officer to sign the OSS and do act to represent the Bidder.

Financial Documents

- (k) The prospective bidder's **Audited Financial Statements**, showing, among others, the prospective bidder's:

"Total and Current Assets and Liabilities, stamped "received" by the BIR or its duly accredited and authorized institutions, for the preceding calendar year which should not be earlier than two (2) years from the date of bid submission;"

and

- (l) The prospective bidder's computation of **Net Financial Contracting Capacity (NFCC)**.

Class "B" Documents

- (m) If applicable, duly signed **Joint Venture Agreement (JVA)** in accordance with RA No. 4566 and its IRR in case the joint venture is already in existence;



Republic of the Philippines
National Kidney and Transplant Institute
Bids and Awards Committee
 East Avenue, Quezon City 1100
 8981-0300 / 9881-0400 local 1156/1186
<http://www.nkti.gov.ph/>

	<p>or duly notarized statements from all the potential joint venture partners stating that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful.</p> <p style="text-align: center;">FINANCIAL COMPONENT ENVELOPE</p> <p>(n) Original of duly signed and accomplished Financial Bid Form; and <i>Other documentary requirements under RA No. 9184</i></p> <p>(o) Original of duly signed Bid Prices in the Bill of Quantities; and</p> <p>(p) Duly accomplished Detailed Estimates Form, including a summary sheet indicating the unit prices of construction materials, labor rates, and equipment rentals used in coming up with the Bid; and</p> <p>(q) Cash Flow by Quarter.</p>						
10.3	<p>i. A current and valid PCAB License (General Building) – for Government Projects</p> <p>i. Specialty Works (Electrical Works)</p> <p>ii. In case of Joint Ventures (JV), a valid Special PCAB License, and registration for the type and cost of the contract for this Project. Provided, that at least one (1) of the JV partners must possess all the above Classification and Category pursuant to GPPB NPM. 0623-2009 dated November 27, 2009)</p>						
10.4	<p>The key personnel must meet the required minimum years of experience set below:</p> <p><u>Key Personnel</u></p> <p>a. Electrical Engineer</p> <p>a. Licensed Electrical Engineer</p> <p>b. At least three (3) years of experience in electrical works</p> <p>b. Construction Safety and Health Officer</p> <p>a. Must be a DOLE Accredited Safety Officer</p> <p>b. At least three (3) years of experience in electrical works</p>						
10.5	<p>The minimum major equipment requirements are the following (if applicable):</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 33%; text-align: left;">Equipment</th> <th style="width: 33%; text-align: left;">Capacity</th> <th style="width: 33%; text-align: left;">Number of Units</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Equipment	Capacity	Number of Units			
Equipment	Capacity	Number of Units					



Republic of the Philippines
National Kidney and Transplant Institute
Bids and Awards Committee
 East Avenue, Quezon City 1100
 8981-0300 / 9881-0400 local 1156/1186
<http://www.nkti.gov.ph/>

15.1	<p>The bid security shall be in the form of a Bid Securing Declaration or any of the following forms and amounts:</p> <ol style="list-style-type: none"> 1. The amount of not less than 2% of the ABCif bid security is in cash, cashier's/manager's check, bank draft/guarantee or irrevocable letter of credit; 2. The amount of not less than 5% of the ABC if bid security is in Surety Bond.
16	<p>Each Bidder shall submit one original copy and copy 1 of the first and second components of its Bid arranged, numbered, tabbed in a soft book binded folders.</p> <div style="text-align: center;"> <p>SEALING AND MARKING OF BIDS (Two-Envelope System)</p> </div>
19.2	<p>Partial bids shall not be allowed.</p>
20	<p>Within a non-extendible period of five (5) calendar days from receipt by the Bidder of the notice from the BAC that it submitted the Lowest Calculated Bid, the Bidder shall submit:</p> <ol style="list-style-type: none"> (a) Original/Certified true copy of Latest income and business tax returns and paid through the BIR Electronic Filing and Payment System (eFPS); (b) Original/Certified true copy of other appropriate licenses and permits required by law and stated in the Bidding Documents. (c) Original/Certified true copy of Bureau of Internal Revenue (BIR) Registration Certificate or equivalent for foreign bidder; (d) Certified True Copy of the latest <u>General Information Sheet (GIS)</u> duly filed and received by SEC, or equivalent for foreign bidder; (e) Certificate of PhilGEPS Registration (Platinum Member);
21	<p>Additional contract documents relevant to the Project that may be required by existing laws and/or the Procuring Entity, such as construction schedule and S-curve, manpower schedule, construction methods, equipment utilization schedule, construction safety and health program approved by the DOLE, and other acceptable tools of project scheduling.</p>



Republic of the Philippines
National Kidney and Transplant Institute
Bids and Awards Committee
East Avenue, Quezon City 1100
8981-0300 / 9881-0400 local 1156/1186
<http://www.nkti.gov.ph/>

21.1	<p>The LCB shall submit the following additional documents in two (2) sets within a non-extendible period of five (5) calendar days from receipt of the notification.</p> <ol style="list-style-type: none">1. Contracting Company's Profile (using NKTi Template);2. Certificate of Site Inspection issued by NKTi-General Services Division (GSD);3. Product Data Sheet (include dimensions and data on features, performance, electrical characteristics, ratings and finishes);4. Transformer Factory Test Reports/Results including Torque Value applied to all hardware specially on bushings;5. Certificate of Warranty that the contractor shall provide at least one (1) year warranty on equipment and workmanship upon receipt of Final Acceptance;6. Materials Safety Data Sheet (Insulating Oil);7. Certificate of Original Equipment Manufacturer (OEM) or an Authorized Distributor with registered business specialized in construction, supply installation, testing and commissioning of electrical equipment specifically Power Transformers;8. Certificate of Guarantee that the equipment and materials to be installed are brand new;9. Personnel Requirement:<ol style="list-style-type: none">i. One (1) Electrical Engineer<ol style="list-style-type: none">a. Licensed Electrical Engineerb. At least three (3) years of experience in handling electrical worksii. One (1) Construction Safety and Health Officer<ol style="list-style-type: none">a. Must be a DOLE Accredited Safety Officerb. At least three (3) years of experience in handling electrical works
------	---



Revised Section V. Special Conditions of Contract

GCC Clause	
2	The Intended Completion Date is One Hundred Twenty (120) Ninety (90) calendar days from the date of acceptance of the Notice to Proceed
4.1	The Procuring Entity shall give possession of all parts of the Site to the Contractor upon receipt of the Notice to Proceed.
6	The site investigation reports are: <i>[list here the required site investigation reports.]</i>
7.2	<i>[Select one, delete the other.]</i> <i>[In case of permanent structures, such as buildings of types 4 and 5 as classified under the National Building Code of the Philippines and other structures made of steel, iron, or concrete which comply with relevant structural codes (e.g., DPWH Standard Specifications), such as, but not limited to, steel/concrete bridges, flyovers, aircraft movement areas, ports, dams, tunnels, filtration and treatment plants, sewerage systems, power plants, transmission and communication towers, railway system, and other similar permanent structures:]</i> Fifteen (15) years. <i>[In case of semi-permanent structures, such as buildings of types 1, 2, and 3 as classified under the National Building Code of the Philippines, concrete/asphalt roads, concrete river control, drainage, irrigation lined canals, river landing, deep wells, rock causeway, pedestrian overpass, and other similar semi-permanent structures:]</i> Five (5) years. <i>[In case of other structures, such as bailey and wooden bridges, shallow wells, spring developments, and other similar structures:]</i> Two (2) years.
10	<i>[Select one, delete the other:]</i> a. Dayworks are applicable at the rate shown in the Contractor's original Bid. b. No dayworks are applicable to the contract.
11.1	The Contractor shall submit the Program of Work to the Procuring Entity's Representative within seven (7) calendar days upon receipt of the Notice of Award.
11.2	The amount to be withheld for late submission of an updated Program of Work is 1/1000 of ten (10%) of the ABC.
13	The amount of the advance payment shall not exceed 15% of the total contract price.



Republic of the Philippines
National Kidney and Transplant Institute
Bids and Awards Committee
East Avenue, Quezon City 1100
8981-0300 / 9881-0400 local 1156/1186
<http://www.nkti.gov.ph/>

14	Materials and equipment delivered on the site but not completely put in place shall be included for payment.
15.1	The date by which operating and maintenance manuals are required is <u>one week upon acceptance of the project (if applicable)</u> The date by which “as built” drawings are required is <u>one week upon acceptance of the project</u>
15.2	The amount to be withheld for failing to produce “as built” drawings and/or operating and maintenance manuals by the date required is 1/1000 of ten (10%) of the ABC.

Revised Section VI. Specifications

PART 1 – GENERAL

1.0 Project Description:

1.01 Project Title:

One (1) Lot Supply, Delivery, Installation, Testing and Commissioning of one (1) unit brand new 1500kVA Power Transformer including dismantling, decommissioning, and trade-in of the old and defective unit at Diagnostic Power Center.

1.02 Project Cost:

The Total Approved Budget for the Contract is **Four Million Two Hundred Thousand Pesos (PhP4,200,000.00)**.

1.03 Project Completion:

The project shall be completed within **one hundred twenty (120) ~~ninety (90)~~** calendar days upon receipt of Notice to Proceed.

1.04 Background and Objective:

Power stability and availability is of great importance for hospital operation. Un-planned power interruption due to sudden equipment breakdown can cause partial stoppage of some hospital equipment operation.

Maintenance of electrical equipment such as transformers is very vital. Planned replacement of such equipment before the sudden breakdown will give ample time to make contingencies and precautions.

1.05 General Requirements:

- A. The project shall include inspection of the actual site/location, ingress, egress, and drop-off point, including measurements of the existing area and concrete pad.
- B. The project shall include inspection of the existing transformer and tapping points for the Primary/High Voltage (HV) and Secondary/Low Voltage (LV) cables.
- C. The project shall include dismantling, lifting, loading, and hauling out of the old and defective 1500kVA "Cooper" Power Transformer (S/N: 959002322) as part of the trade-in.

CONFORME:
<i>(Company Name)</i>
<i>(Name and Signature of Authorized Representative)</i>

- D. The project shall include delivery, lifting, hauling, loading/unloading, positioning, and installation of the brand new 1500kVA Power Transformer.
- E. The project shall include testing and commissioning of the brand new 1500kVA Power Transformer.

1.06 Submittals:

- A. Product Data: Include dimensions and data on features, performance, electrical characteristics, ratings, and finishes.
- B. Transformer Factory Test Reports/Results including Torque Value applied to all hardware specially on bushings.
- C. Warranty: One (1) year warranty on equipment and workmanship upon receipt of Final Acceptance.
- D. Materials Safety Data Sheet (Insulating Oil).

1.07 Quality Assurance:

- A. The equipment and workmanship shall comply with but not limited to the following latest editions of Codes and Standards.
 - 1. Codes:
 - Philippine Electrical Code (Latest Edition)
 - Applicable Local Ordinances
 - 2. Standards:
 - National Electrical Manufacturer's Association (NEMA)
 - National American Society for Testing and Materials (ASTM)
 - International Electro-Technical Commission (IEC)
 - International Organization for Standardization (ISO)
 - Institute of Electrical and Electronics Engineers (IEEE)
 - American National Standards Institute (ANSI)
- B. The prospective Bidder/Contractor shall be the Original Equipment Manufacturer (OEM) or an Authorized Distributor with registered business specialized in construction, supply, installation, testing and commissioning of electrical equipment specifically Power Transformers. Project In-Charge shall be one (1) duly Licensed Electrical Engineer and one (1) certified Safety Officer. The contractor must have a valid and appropriate PCAB License for Government Projects (Electrical Works).

CONFORME:
<i>(Company Name)</i>
<i>(Name and Signature of Authorized Representative)</i>

- C. The Original Equipment Manufacturer (OEM), local or international, must operate a quality assurance system that complies with ISO 9001/ISO 14001 or equivalent.
- D. All equipment, including accessories, shall be packed and securely clamped against movement in robust packing cases to ensure safe transit from origin to the agreed point of delivery.

Transformer shall be supplied filled with insulating oil. The weight and volume of oil in the transformer shall be clearly stated.

Internal surfaces of equipment and accessories shall be sealed off by means of gaskets and blanking off plates. Equipment and surfaces liable to deterioration due to condensation shall be protected by packs of silica gel or other approved desiccant.

PART 2 – PRODUCTS

1.0 Equipment:

Transformer shall comply with the following **minimum** requirement:

Description	Requirement
Power Rating:	1500 kVA
Rated Voltage:	
<i>High Voltage</i>	34.5 KV
<i>Low Voltage</i>	400Y/231
Frequency:	60 Hz
Phase:	3 Phase
Vector Group:	Yn/Yo
Temperature Rise:	65°C
Voltage Variation:	Off-load Tap Changer with 5 Positions in HV Winding giving $\pm 2 \times 2.5\%$
Type:	Dead Front, Loop-Feed
Standard:	IEC, ANSI/IEEE, ISO, NEMA, ASTM or equivalent
Cooling Liquid:	Dielectric Fluid or Environment-Friendly High Fire Point Mineral Oil, Self-Cooled, Polychlorinated Biphenyl (PCB) Free
Cooling Type:	KNAN/ONAN
Winding Materials:	Copper
Mounting:	Outdoor, Pad Mount (existing)

PART 3 – EXECUTION/INSTALLATION

1.0 Examination/Inspection:

- A. Examine/inspect existing transformer location, concrete pad and other elements for compliance with space allocations, tolerance, hazards, and other conditions affecting installation. Any modifications on the existing concrete pad shall be borne by the

CONFORME:
<i>(Company Name)</i>
<i>(Name and Signature of Authorized Representative)</i>

contractor. Replace/retrofit, if deemed necessary to accommodate the new transformer.

- B. Examine/inspect existing transformer specifically the High Voltage (Primary) and Low Voltage (Secondary) cables and bushings prior to ordering and manufacturing of the equipment. Any modifications on the existing tapping points, primary and secondary cables, shall be borne by the contractor.

2.0 Delivery and Installation:

- A. Mobilization of personnel and equipment.
- B. Dismantling, decommissioning, and hauling out of old and defective "Cooper" 1500kVA Power Transformer as part of the trade-in. Including retrieval of the insulating oil, it shall be placed in an appropriate sealed container for proper disposal thru a DENR accredited TSD.
- C. The Contractor shall use due care and diligence in removing, replacing, adjusting, cutting, drilling, and installing the equipment. Should any damage, due to the execution of this Contract, occur to the existing or adjacent facilities/utilities, shall be repaired/restored by the Contractor without charge. Coordinate with the General Services Division (GSD) for any actions/work activity.
- D. Delivery, lifting, hauling, rigging, loading/unloading, positioning, and installation of the brand new 1500kVA Power Transformer to the designated concrete pad.
- E. Cleaning and clearing of debris and other scrap materials of the site.

3.0 Field Testing and Commissioning:

- A. Perform tests and inspections. Engage a factory-authorized service representative to inspect, test, and adjust components, assemblies, and equipment installations, including cable connections and tightness of all hardware especially bushing clamp bolt and nuts.
- B. Transformers shall be tested in accordance with the above-mentioned standards and other applicable standards shall include but not limited to the following type of test:
 - a. Transformer Turns Ratio test
 - b. Insulation Resistance Test
 - c. Winding Resistance Test
 - d. Insulation Power Factor Test
 - e. Excitation Current Measurement Test
 - f. Grounding Integrity Test
 - g. Polarization Index Test
 - h. Oil Dielectric Breakdown Voltage Test
 - i. Swift Frequency Response Analysis Test
 - j. Impedance Voltage Test

CONFORME:
<i>(Company Name)</i>
<i>(Name and Signature of Authorized Representative)</i>

- C. Primary cables (existing) shall be tested prior to energization:
 - a. Insulation Resistance Test
 - b. DC Hi-Pot Test

- C. All tests and adjustments shall be set in the field by the Contractor in accordance with the approved coordination study. Correct defects in the work provided by the Contractor and repeat tests until the work is in compliance with the contract requirement.

- E. Prepare and submit test and inspection reports.

<p>Conforme:</p> <p>Name: _____</p> <p>Legal Capacity: _____</p> <p>Signature: _____</p> <p>Duly authorized to sign the Bid for and behalf of: _____</p>

CONFORME:
<i>(Company Name)</i>
<i>(Name and Signature of Authorized Representative)</i>